

FIRST FLOOR PLAN:

SCALE: 1/4" = 1'-0"

Each door leaf shall provided at least a clear opening width of 32".

GENERAL NOTES

- 1) All dimensions are to the center of the member unless otherwise noted.
- 2) All interior finishes are to have a fire spread rating of 0.5 per NFPA 101, Section 803.2.1.1.1.
- 3) All interior finishes are to have a fire spread rating of 0.5 per NFPA 101, Section 803.2.1.1.1.1.

SEE: Sec. 101.01 of the Philadelphia Fire Code for disabled accessibility and ANSI A117.1 - 1997

Separate permit required

B-408.4 Fuel-dispensing areas: Fuel-dispensing areas shall be located on the level nearest grade. Public garages with fuel-dispensing areas shall be completely separated from any other use of the building. The fuel-dispensing area shall have a minimum fire-resistance rating of 2 hours. The floors of the fuel-dispensing areas shall be graded to a floor slope of one percent in the direction of the drainage system. The drainage system shall conform to the requirements of the International Building Code. The fuel-dispensing area shall be equipped with an automatic fire-extinguishing system in accordance with Chapter 9.

B-408.4.1 Fuel-dispensing systems: All fuel-dispensing systems shall conform to the requirements of the International Building Code.


B-408.5 Ventilation: All public garages shall be ventilated in accordance with the mechanical code and Air Management Department of Public Health. Fuel-dispensing areas shall be mechanically ventilated.

B-408.6 Special hazards: Any process conducted in a building shall be designed to prevent the release of flammable or toxic vapors. Any process which involves volatile flammable solvents shall be designed to prevent the release of such vapors. The quantity of flammable liquids stored in tanks, in special garages - except in underground storage tanks, in special garages - shall not be more than 5 gallons (20 L) in approved safety cans.

J.D. BYRIDER
BRIDGE STREET
PHILADELPHIA, PA

55 PLANK AVE.
PAOLI PA
19301
PHONE: (610) 947-8789
FAX: (610) 296-8910
E-MAIL: RICHDSIGN@AOL.COM

RHC
DESIGN INC.



REVISIONS:	9/18/02 - REMOVED ADDITION
DATE:	08-27-02
FILE NO:	02028
SCALE:	1/4" = 1'-0"
TITLE:	WORKING DRAWINGS
SHEET:	A-2
OF 5 SHEETS	